

COPY OF FIRE SAFETY CERTIFICATE

FIRE AND RESCUE SERVICE STATION TRIPPLICANE, CHENNAI-600 002

SL.NO:40/2026

REG NO: 246/V/TPN/2026

DATE: 16.05.2026

NO OBJECTION CERTIFICATE



Sub: Fire & Rescue Service – Triplicane Fire and Rescue Service Station-No
Objection certificate building/To correct a school building/Issue Recognition-
Reg

1. Govt. Order No.122. School Education (Primary Education (2) Department
Date: 14.09.2014
2. Govt. Order No.123. School Education (Primary Education (2) Department
Date: 14.09.2014

Application Received From the Principal, **THE HINDU SENIOR SEC SCHOOL.**

As per the Govt Order and the Application, **M/S: THE HINDU SENIOR SEC SCHOOL,**
Situating at No: **83, BIG STREET, TRIPPLICANE, CHENNAI-600 005,** Was Inspected by the Station
Officer Mr.R.Jaganathan. No 16-05-2026. There is No Objection from the Department of Fire & Rescue
Services a School Building at this place or to Issue School Recognition. (NOC Period Time
16.05.2026 to 15.05.2029)

CONDITIONS

- (A) This license is valid for Three year from the date of issue,
- (B) All the extinguishers have to be recharged and maintained periodically as per code in 2190
- (C) Fire and safety system arrangement have to be provided in accordance with to requirement of
NBC-part IV- Fire and life safety 2000
- (D) This NOC is not applicable for swimming pool


16.05.26
நினைவக அலுவலர்
தீயகாப்பு மற்றும் மீட்டிங் பணிகளின் துறை
திருவள்ளூர்-சென்னை-600 002

TO, THE PRINCIPAL,
M/S: THE HINDU SENIOR SEC SCHOOL,
NO: 83, BIG STREET,
TRIPPLICANE, CHENNAI-600 005.

Copy: District Officer, Chennai Central District.

FIRE AND RESCUE SERVICE STATION
TRIPPLICANE, CHENNAI-600 002

SL.NO:39/2026

REG NO: 245/V/TPN/2026

DATE: 14.05.2026

NO OBJECTION CERTIFICATE



Sub: Fire & Rescue Service –Triplicane Fire and Rescue Service Station-No
Objection certificate building/To correct a school building/Issue Recognition-
Reg


Ref: 1. Govt. Order No.122. School Education (Primary Education (2) Department
Date: 14.09.2014
2. Govt. Order No.123. School Education (Primary Education (2) Department
Date: 14.09.2014

Application Received From the Principal, **THE HINDU SENIOR SECONDARY SCHOOL,**

As per the Govt Order and the Application M/S: **THE HINDU SENIOR SECONDARY SCHOOL,** Situated at **NO: 87, BIG STREET, TRIPPLICANE, CHENNAI-600 005,** Was Inspected by the Station Officer Mr.R.Jaganathan. As on :13-05-2026, there is No Objection from the Department of Fire & Rescue Services a School Building at this place or to Issue School Recognition. (NOC Period Time 14.05.2026 to 13.05.2029)

CONDITIONS

- (A) This license is valid for Three year from the date of issue,
- (B) All the extinguishers have to be recharged and maintained periodically as per code in 3190
- (C) Fire and safety system arrangement have to be provided in accordance with to requirement of NBC-part IV- Fire and life safety 2000
- (D) This NOC is not applicable for swimming pool


நிலைய அலுவலர்
14.05.26
தென்மேல் மன்றம் மீட்டிங் பஸ்டிசன் நிலையம்
திருவல்லிக்கேணி, சென்னை-600 002

TO, THE PRINCIPAL,
M/S: THE HINDU SENIOR SECONDARY SCHOOL,
NO: 87, BIG STREET,
TRIPPLICANE, CHENNAI-600 005.

Copy: District Officer, Chennai Central District.

FIRE AND RESCUE SERVICE STATION
TRIPPLICANE, CHENNAI-600 002

SL.NO:38/2026
REG NO: 244/V/TPN/2026

DATE: 14.05.2026

NO OBJECTION CERTIFICATE



Sub: Fire & Rescue Service –Triplicane Fire and Rescue Service Station-No
Objection certificate building/To correct a school building/Issue Recognition-
Reg

1. Govt. Order No.122. School Education (Primary Education (2) Department
Date: 14.09.2014
2. Govt. Order No.123. School Education (Primary Education (2) Department
Date: 14.09.2014

Application Received From the Principal, **THE HINDU SENIOR SECONDARY SCHOOL,**

As per the Govt Order and the Application M/S: **THE HINDU SENIOR SECONDARY SCHOOL,** Situated at **NO: 88, BIG STREET, TRIPPLICANE, CHENNAI-600 005,** Was Inspected by the Station Officer Mr.R.Jaganathan. As on:13-05-2026, there is No Objection from the Department of Fire & Rescue Services a School Building at this place or to Issue School Recognition. (NOC Period Time 14.05.2026 to 13.05.2029)

CONDITIONS

- (A) This license is valid for Three year from the date of issue,
- (B) All the extinguishers have to be recharged and maintained periodically as per code in 2190
- (C) Fire and safety system arrangement have to be provided in accordance with to requirement of NBC-part IV- Fire and life safety 2000
- (D) This NOC is not applicable for swimming pool


16.05.26
நிலைய அலுவலர்
தீயணைப்பு மற்றும் மீட்டிங் பணிகளை திட்டமிடும்
தீயணைப்பு நிலையம், திருவள்ளூர், சென்னை-600 002

TO, THE PRINCIPAL,
M/S: THE HINDU SENIOR SECONDARY SCHOOL,
NO: 88, BIG STREET,
TRIPPLICANE, CHENNAI 600 005.

Copy: District Officer, Chennai Central District.

FIRE AND RESCUE SERVICE STATION
TRIPPLICANE, CHENNAI-600 002

SL.NO:36/2026
REG NO: 243/V/TPN/2026

DATE: 14.05.2026

NO OBJECTION CERTIFICATE



Sub: Fire & Rescue Service –Triplicane Fire and Rescue Service Station-No
Objection certificate building/To correct a school building/Issue Recognition-
Reg

- Ref: 1. Govt. Order No.122. School Education (Primary Education (2) Department
Date: 14.09.2014
2. Govt. Order No.123. School Education (Primary Education (2) Department
Date: 14.09.2014

Application Received From the Principal, **THE HINDU SENIOR SECONDARY SCHOOL,**

As per the Govt Order and the Application **M/S:THE HINDU SENIOR SECONDARY SCHOOL,** Situated at **NO: 22(15) PEYALWAR STREET, TRIPPLICANE, CHENNAI-600 005,** Was Inspected by the Station Officer Mr.R.Jaganathan.No13-05-2026, there is No Objection from the Department of Fire & Rescue Services a School Building at this place or to Issue School Recognition. (NOC Period Time 14.05.2026 to 13.05.2029)

CONDITIONS

- (A) This license is valid for Three year from the date of issue,
(B) All the extinguishers have to be recharged and maintained periodically as per code in 2190
(C) Fire and safety system arrangement have to be provided in accordance with to requirement of NBC-part IV- Fire and life safety 2000
(D) This NOC is not applicable for swimming pool


16.05.26
நிலைய அலுவலர்
திரிபலகாண்டி மீட்டிபுலானிவன் நிலையம்
திருவக்கிங்கோணி, சென்னை-600 002

TO, THE PRINCIPAL,
M/S: THE HINDU SENIOR SECONDARY SCHOOL,
NO: 08(15) PEYALWAR STREET,
TRIPPLICANE, CHENNAI-600 005.

Copy: District Officer, Chennai Central District.